

The D.D.O.,
Govt. Model High School,
Sector-45/C, UT, Chandigarh.

The Chief Engineer,
Chandigarh Administration.

Memo No. GMHS/45/2016/ 260-62
Dated Chandigarh, the 1-8-16

Subject: Request for installation of Fire Fighting System in the School Building.


Please refer on the subject cited above.

In this connection it is submitted that officials of Municipal Corporation, Chandigarh (Fire & Emergency Services) inspected the school building on 23-10-2015. During inspection, it was observed by the inspecting team that school building structure is above 15 mtrs and comes under Group B, Sub Div. B-2. The inspecting team directed vide letter Memo No. CFO/2015/528 dated 4-11-2015 (copy enclosed) for installing the following fire fighting system in the school building :-

1. Fire Extinguishers.
2. Hose reel system
3. Down comer system
4. Manually operated electric fire alarm system.
5. Terrace water tank for fire of 25,000 ltrs capacity with pump minimum pressure of 2.0 kg/cm².
6. Exit sign boards.

In view of the above it is requested to install the above said fire fighting system in the school building at the earliest to avoid any untoward incident.

DA : As above.



D.D.O.,
Govt. Model High School,
Sector-45/C, UT, Chandigarh.

Endst. No. GMHS/45C/2016/

Dated :

A copy is forwarded to the following for information and necessary action please :-

- 1 The Director School Education, Chandigarh Administration.
- 2 The District Education Officer, Chandigarh Administration


D.D.O.,
Govt. Model High School,
Sector-45/C, UT, Chandigarh.

MUNICIPAL CORPORATION, CHANDIGARH
(Fire & Emergency Services)

The Headmistress,
Govt. Model High School,
Sector -45-C,
Chandigarh.

officer
N/A
09/11/15
[Signature]

Memo No. CFO/2015/ 528
Dated, Chandigarh the : 04/11/15

Subject :- Reg.: Issue of Fire Safety Certificate – Installation of fighting system.

Reference your letter no. GMHS/45/2015/269 dated 29.09.15 on the subject cited above.

Inspection was carried out on 23.10.15, to check the fire fighting system installed in the Govt. Model High School and during inspection it was found that only fire extinguishers (12 nos.), while as per school building structure i.e. above 15 mtr. the school is comes under Group B, Sub. Div. B-2). hence the following fire fighting system is required to be installed :-

1. Fire extinguishers.
2. Hose reel system.
3. Down comer system.
4. Manually operated electric fire alarm system.
5. Terrace water tank for fire of 25,000 ltr. Capacity with pump minimum pressure of 2.0 kg/cm².
6. EXIT sign boards.

Therefore, you are requested to install the abovesaid fire fighting system under intimation to this office, to proceed further into the matter of NOC

[Signature]
Chief Fire Officer,
Fire & Emergency Services,
Chandigarh

Endst.No CFO/2015/

Dated

A copy of the above is forwarded to the Station Fire Officer, Fire Station Sector-32, Chandigarh for information and necessary action



GOVT MODEL HIGH SCHOOL SECTOR, 45-C CHANDIGARH PH: 0172 2925392

To

The District Education Office
Chandigarh Administration
Chandigarh.


Memo No. GMHS/45/2021/412
Dated, 14.07.2021

**Subject: Application for sanction for the installation of Fire Safety System
in the School Building for upgradation of school.**

Respected Sir

In this connection, it is submitted that our school was inspected for fire safety and certain items were mandatory for installing in the school as mentioned in the letter.

You are requested to provide us sanction for the installation of Fire Safety Equipments.


Headmistress
Govt. Model High School
Sector 45
CHANDIGARH

From

The D.D.O.
Govt. Model High School,
Sector-45/C, UT, Chandigarh.

To

The Chief Engineer,
Chandigarh Administration.

Memo No. GMHS/45/2016/ 260-62
Dated Chandigarh, the 1-8-16

Subject Request for installation of Fire Fighting System in the School Building.


Please refer on the subject cited above.

In this connection it is submitted that officials of Municipal Corporation, Chandigarh (Fire & Emergency Services) inspected the school building on 23-10-2015. During inspection, it was observed by the inspecting team that school building structure is above 15 mtrs and comes under Group B, Sub Div. B-2. The inspecting team directed vide letter Memo No. CFO/2015/528 dated 4-11-2015 (copy enclosed) for installing the following fire fighting system in the school building :-

1. Fire Extinguishers.
2. Hose reel system
3. Down comer system
4. Manually operated electric fire alarm system.
5. Terrace water tank for fire of 25,000 ltrs capacity with pump minimum pressure of 2 kg/cm².
6. Exit sign boards.

In view of the above it is requested to install the above said fire fighting system in the school building at the earliest to avoid any untoward incident.

DA: As above.



D.D.O.,
Govt. Model High School,
Sector-45/C, UT, Chandigarh.

Enclst. No. GMHS/45C/2016/

Dated :

A copy is forwarded to the following for information and necessary action please :-

The Director School Education, Chandigarh Administration
The District Education Officer, Chandigarh Administration


D.D.O.,
Govt. Model High School,
Sector-45/C, UT, Chandigarh.